

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-1130:133 Page 1 of 1

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** Honeywell Inc., 1500 W. Dundee Road, Arlington Heights IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403

**DESIGN:** Model DELTANET DPC Plus system. Proprietary or central station service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

AP-X/14507015-001	Personal Computer
W1000A/W1000B/W1017A/W1017B	Central Processing Unit
W1001A/W1001B/W1006A/W1006B	Time Share Module
W1003A/W1003B	Pilot Light Module
FS20A/FSS90A	Data Gathering Panel
W1002A/W1002B	Printer and/or Upgrade
W1001/W1006	Operator Terminal
W1003	Annunciator Module
W1004	Control Interface Module
W1008	Transmission Power Supply
W1009	Select-O-Graphic Module
W1020	Data Gathering Panel
1000/1200 series	Data Gathering Panels
W1013	BOC Console
W1012	Peripherals Control Unit
W1014	BOC Printer
W1011	PTR
W1010	CRT
W1021	Access Control Panel

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Burglary and other non-fire functions not examined.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager